



Product Service

Attestation of Conformity

No. N8A 18 05 73976 005

Holder of Certificate: Koenone Co., Ltd.587-9, Iksan-daero,
Iksan-si, Jeollabuk-do 54535
REPUBLIC OF KOREA**Product: Surge protection equipment
(Surge Protective Device)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA01161218**Date,** 2018-05-09

(Harry Kwon)



CE After preparation of the necessary technical documentation as well as the EU conformity declaration the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8A 18 05 73976 005

Model(s): **KOP-C-80P**

Parameters:

Rated input voltage:	200-240 V a.c.
Rated frequency:	50/60 Hz
Type 2 (Class II test):	40 kA
Maximum continuous operating voltage U_c :	275 V a.c.
Voltage protection level U_p :	2.5 kV

Tested according to: EN 61643-11:2012